

**澳门特别行政区海关**  
**第 08/2017/DAF/SA 号 公开招标**  
**“数据中心零中断解决方案”**  
**问题回复**

1. 问: According to page 32-33/39, seems Customs already got a fiber ring which connected 11 locations. If so, we just need to provide DWDM equipment at 8 of 11 locations. Fiber cable installation is not required.?

答: 海关站点与站点间已有光纤线相连, 按照承投规则第二部份-目标之特定要求, 第 22.9 及 23.2 项, 投标人需为 8 个海关站安装 DWDM 光纤接入设备及设计联机方案, 以满足海关站点与站点间的带宽要求。

2. 问: For the connection from location 8 to 2 & 3, can we make use on the existing fibers at location A, B & C (by patching) to complete the DWDM Ring?

答: DWDM 环的构建及联机方案须由投标公司提供。

3. 问: For the logical topology on page 34/39, please clarify whether they are the logical circuit's requirement of the DWDM network or additional direct connections. If they are DWDM circuit, 青洲 will become a single point of failure. If they are separate circuit, cable installation or network services need done by bidder?

答: 按承投规则第二部份-目标之特定要求, 第 23.3 项, 投标人须提供 3 个“点对点”和“点对多点”的光传输线路连接服务, 该连接服务为逻辑拓扑(logical topology)。

4. 问: Bidder can only provide offer on Section 1 “云数据中心信息设备及软件” or Section 2 “DWDM 光纤网络接入系统”?

答: 招标方案包含“云数据中心信息设备及软件”及“DWDM 光纤网络接入系统”两个项目, 投标人可只投其中一个项目。

5. 问: 有关招标第五部分保证金(MOP200,000.00), 有意选用金管局辖下的保险公司以“保险担保”形式缴交上述临时保证金, 请问是否接纳?

答: 根据《招标方案》第五部份第 17.2 及 17.4 项之规定, 临时保证金可透过现金、银行本票(抬头人为「澳门海关」)或银行担保的形式缴交及银行担保指由获准在本地区经营业务的银行所发出。