

澳門特別行政區海關
第 08/2017/DAF/SA 號 公開招標
“數據中心零中斷解決方案”
問題回覆

1. 問：According to page 32-33/39, seems Customs already got a fiber ring which connected 11 locations. If so, we just need to provide DWDM equipment at 8 of 11 locations. Fiber cable installation is not required. ?

答：海關站點與站點間已有光纖線相連，按照承投規則第二部份-標的之特定要求，第 22.9 及 23.2 項，投標人需為 8 個海關站安裝 DWDM 光纖接入設備及設計連線方案，以滿足海關站點與站點間的帶寬要求。

2. 問：For the connection from location 8 to 2 & 3, can we make use on the existing fibers at location A, B & C (by patching) to complete the DWDM Ring?

答：DWDM 環的構建及連線方案須由投標公司提供。

3. 問：For the logical topology on page 34/39, please clarify whether they are the logical circuit's requirement of the DWDM network or additional direct connections. If they are DWDM circuit, 青洲 will become a single point of failure. If they are separate circuit, cable installation or network services need done by bidder?

答：按承投規則第二部份-標的之特定要求，第 23.3 項，投標人須提供 3 個“點對點”和“點對多點”的光傳輸線路連接服務，該連接服務為邏輯拓樸 (logical topology)。

4. 問：Bidder can only provide offer on Section 1 “雲數據中心資訊設備及軟件” or Section 2 “DWDM 光纖網路接入系統”？

答：招標方案包含“雲數據中心資訊設備及軟件”及“DWDM 光纖網路接入系統”兩個項目，投標人可只投其中一個項目。

5. 問：有關招標第五部分保證金(MOP200,000.00)，有意選用金管局轄下的保險公司以“保險擔保”形式繳交上述臨時保證金，請問是否接納？

答：根據《招標方案》第五部份第 17.2 及 17.4 項之規定，臨時保證金可透過現金、銀行本票(抬頭人為「澳門海關」)或銀行擔保的形式繳交及銀行擔保指由獲准在本地區經營業務的銀行所發出。